

EU Declaration of Conformity

Greenwood Air Management Ltd declare that our **F** Vent product ranges for all domestic and commercial fan ventilation build purposes are RoHS compliant and have been designed to comply with the safety requirements of the following EEC directives :

CE Marking Directive 93/68/ EEC of 22 July 1993

Machinery Directive 93/37/ EEC of 22 June 1998


Specifically concerning product codes : **F** 1,250 FBW and **F** 2,500 FBW Window Vents

We confirm that conformity has been validated by a combination of our design engineering self-certification testing + independent 3rd party testing for Airflow Rate and Pressure to the following BS/EN harmonised standards:-

- BS EN 13141 – 1 2004 Ventilation for buildings for externally & internally mounted air Performance Testing of Components / Products for Residential ventilation – Part 1, Externally and Internally Mounted Transfer Devices
- BS EN 1026:2000 Windows and Door – Air Permeability – Test Method
- BS EN 1027:2000 Windows and Doors – Water-tightness – Test Method.

For the water-tightness test, the vents were tested in the closed position & water spray method 1A was used. The water-tightness tests have been carried out in accordance with the BS EN 1027 test procedure, up to a maximum pressure of 750 Pa.

I hereby declare that the product codes named above, fully comply with all the EU conformity requirements of the directives, as per Test Report BP7024/3RPF/O6 to meet CE Compliance.



Patrick J Reel
Product Realisation Manager
Date: 7th April 2014

PL-EU-2014